

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 287

Dated: 22/02/2024

It is certified that an inspection team headed by Sr. Jitendra Kumar (Name of Officers with designation) from Regional Water Testing Lab, Muzaffarpur (Name of Department/ Office) inspected the **RIYA INTERNATIONAL SCHOOL, State Bank Road, Paroo, Muzaffarpur, Bihar, 843112** on 6/02/2024 (date of inspection) and found that the **RIYA INTERNATIONAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year.

Issued on 10/2/2024 at P.H Division, Motipur

Signature with Seal: [Signature]

Name: Rakesh Kumar Executive Engineer  
P.H. Division Motipur

Designation: .....

Name & Address of the Office / Department: P.H Division, Motipur

To,  
RIYA INTERNATIONAL SCHOOL  
State Bank Road, Paroo,  
Muzaffarpur, Bihar,  
843112

[Signature]  
MANAGER / CORRESPONDENT  
Riya International School  
Paroo, Muzaffarpur

[Signature]  
Principal  
Riya International School  
Paroo, Muzaffarpur

- 1 District - Muzaffarpur
- 2 Block-Paroo
- 3 Panchayat-Paroo south
- 4 Village ward-Paroo south /14
- 5 Name of the Source- Saberns bala

PUBLIC HEALTH DIVISION, MUZAFFARPUR  
 Chemical & Bacteriological Examination Report of Drinking Water Samples

Date: 06/02/2024

Sample collected by :- Chandan Kumar

Name of School- Riya International school

No.	Parameters	Desirable Limit (value in mg/l except pH)	Permissible Limit in absence of Alternative Source	Water testing result (in mg/l)	Remarks
1	Turbidity	1.0 NTU	5.0 NTU	0.90	Analysed sample of water conforms to Indian standard limit (IS 10500:2012)
2	pH	6.5-8.5	No relaxation	7.60	
3	Conductivity	-	600	568	
4	Total Hardness	200	600	324	
5	Alkalinity	200	600	300	
6	Calcium	75	200	60	
7	Magnesium	30	100	42	
8	Chloride	250	1000	46	
9	Iron	0.3	NR	0.30	
10	Nitrate	45	No relaxation	NT	
11	Fluoride	1	1.5	0.20	
12	TDS	500	2000	370	
13	Arsenic	0.01	No relaxation	NT	
14	Bacteriological	-	-	Negative (-)	

Note: (i) Drinking water Specification second Revision -15:10500:2012, (ii) BDL means Below Detection limit., (iii) NR means no relaxation.  
 (a) Throughout any year 35% of the samples should not contain coliform organism in 100 ml.  
 (b) No sample should contain more than 10 coliform organisms per 100 ml.  
 (c) coliform organisms should not be detected in 100 ml of any two consecutive samples.

*Chandran*  
 Chemist 6.02.2024

R.W.T.L, MUZAFFARPUR

*Riya International*  
 MANAGER / CORESPONDENT  
 Riya International School  
 Paroo, Muzaffarpur

*Principal*  
 PRINCIPAL  
 Riya International School  
 Paroo, Muzaffarpur